



BUILDING ADVISORY SERVICES BRANCH
BUILDING NOTE

Contact Officer: PETER HADFIELD

Edition Number: 39 – 7/06/2001

SHOWER & BASIN WASTES.

AS/NZ 3500 2.2: 1996. SECTION 11 FIXTURES AND APPLIANCES.

There has been a number of instances where undersized Shower grates and Basin Plug & Waste's have been installed.

Certifying Plumbers are reminded that AS/NZ 3500 requires

2.2 – 11.18.1. An individual shower shall be fitted with a minimum DN 80 grate, and shall either be connected to a minimum DN 40 trap or connected untrapped as permitted in Table 4.4.

2.2- 11.8 Basins shall be fitted with DN 40 trap and waste with a minimum discharge pipe size of 40mm.

Fabio Finocchiaro
Director
Building Control

12 June 2001