

2.3.2 Conditionally acceptable

If from Table 2.1, the building site is classified as 'conditionally acceptable', the maximum aircraft noise levels for the relevant aircraft and the required noise reduction should be determined from the procedure of Clauses 3.1 and 3.2, and the aircraft noise attenuation to be expected from the proposed construction should be determined in accordance with Clause 3.3 (see Notes 1 and 3 of Table 2.1).

2.3.3 Unacceptable

If, from Table 2.1 the building site is classified as 'unacceptable', construction of the proposed building should not normally be considered. Where in the community interest redevelopment is to occur in such areas, e.g. a hotel in the immediate vicinity of an aerodrome, refer to the notes to Table 2.1.

TABLE 2.1
BUILDING SITE ACCEPTABILITY BASED ON ANEF ZONES
(To be used in conjunction with Table 3.3)

Building type	ANEF zone of site		
	Acceptable	Conditionally acceptable	Unacceptable
House, home unit, flat, caravan park	Less than 20 ANEF (Note 1)	20 to 25 ANEF (Note 2)	Greater than 25 ANEF
Hotel, motel, hostel	Less than 25 ANEF	25 to 30 ANEF	Greater than 30 ANEF
School, university	Less than 20 ANEF (Note 1)	20 to 25 ANEF (Note 2)	Greater than 25 ANEF
Hospital, nursing home	Less than 20 ANEF (Note 1)	20 to 25 ANEF	Greater than 25 ANEF
Public building	Less than 20 ANEF (Note 1)	20 to 30 ANEF	Greater than 30 ANEF
Commercial building	Less than 25 ANEF	25 to 35 ANEF	Greater than 35 ANEF
Light industrial	Less than 30 ANEF	30 to 40 ANEF	Greater than 40 ANEF
Other industrial	Acceptable in all ANEF zones		

NOTES:

- 1 The actual location of the 20 ANEF contour is difficult to define accurately, mainly because of variation in aircraft flight paths. Because of this, the procedure of Clause 2.3.2 may be followed for building sites outside but near to the 20 ANEF contour.
- 2 Within 20 ANEF to 25 ANEF, some people may find that the land is not compatible with residential or educational uses. Land use authorities may consider that the incorporation of noise control features in the construction of residences or schools is appropriate (see also Figure A1 of Appendix A).
- 3 There will be cases where a building of a particular type will contain spaces used for activities which would generally be found in a different type of building (e.g. an office in an industrial building). In these cases Table 2.1 should be used to determine site acceptability, but internal design noise levels within the specific spaces should be determined by Table 3.3.
- 4 This Standard does not recommend development in unacceptable areas. However, where the relevant planning authority determines that any development may be necessary within existing built-up areas designated as unacceptable, it is recommended that such development should achieve the required ANR determined according to Clause 3.2. For residences, schools, etc., the effect of aircraft noise on outdoor areas associated with the buildings should be considered.
- 5 In no case should new development take place in greenfield sites deemed unacceptable because such development may impact airport operations.